

अभियांत्रिकी विभाग/ENGINEERING DEPARTMENT
उत्तरी परिसर /(NORTH CAMPUS)
दिल्ली विश्वविद्यालय/UNIVERSITY OF DELHI
दिल्ली-110007/DELHI-110007

REF. NO. CE/DU/ (2024-2025)/ 4275

DATED: 27-3-25

To

Dr. Garima Bharti,
Vice Principal, HOS
Delhi University Social Centre School
Block-C, Maurice Nagar
Delhi-110007

Sub: Issuing of Certificates in order to remove the objections raised by Public School Branch.


Respected Madam,

This is in reference to your letter no. DUSCSS/2024-25/3805 dt. 26.03.2025, the pointwise reply is as under: -

1. As per central Ground Water Commission guidelines, the rain water harvesting is not required where underground water table/level is above 7.0 mtr. The water table/level is the School Campus is about 4 mtr.
2. The Building is being constructed by the CPWD. The CPWD is the authority to issue the completion certificate.
3. The building constructed by CPWD and the building is structurally stable as the structural drawings were vetted by DTU. (Delhi Technological University)
4. The drawings for the above building were duly approved by fire authority and all the fire norms are being followed.

Thanking you,

Sincerely,


Chief Engineer

मुख्य अभियन्ता/Chief Engineer
अभियांत्रिकी विभाग/Engineering Department
दिल्ली विश्वविद्यालय/University of Delhi
दिल्ली-110007/Delhi-110007