

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/2022/School/ ND2/1251

Dated 18/11/2022

FIRE SAFETY CERTIFICATE

Certified that the **Delhi University Social Centre Co-ed Secondary School** located at **Block-C, Maurice Nagar, Delhi-110007** comprised of **02 blocks (ground & ground plus first floor only)** owned/ occupied by the **Delhi University Social Centre Co-ed Secondary School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no. 262-362 dated 17.01.2005 and verified by the officer concerned of Fire Service on **02.11.2022** in the presence of **Mrs. Vibha Sharma (Teacher)** and that the building/premises is fit for occupancy "**Group B Educational**" with effect from 18/11/2022 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 18/11/2022 at New Delhi


(Atul Garg)
Director
Ph:-011-23474000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Delhi University Social Centre Co-ed Secondary School located at Block-C, Maurice Nagar, Delhi-110007.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".