
	DELHI JAL BOARD: GNCTD ZONAL LABORATORY WTP WAZIRABAD, DELHI-54	
---	--	---


TEST REPORT			
Sample ID	Ref. No. D.J.B/DTQC/Wzd./2024-25/Paid-179		
Location /Address of Sample	Delhi University Social Center School, Maurice Nagar, Delhi-110007		
Letter Reference No.	DUSCSS/2024-25/3418	Ref. Letter Date	05.12.2024
Challan No.	210	Challan Date	09.12.2024
Sample Collection date	10.12.2024	Analysis start date	09.12.2024
Any other Information	--	Analysis end date	11.12.2024
		Reporting date	12.12.2024


TEST RESULTS					
S.No	Parameters	Unit	As per the IS 10500		Outlet (RO)
			Acceptable limit	Permissible limit	
1	Colour	CU	5 (Max)	15 (Max)	2.0
2	Odour	Agreeable	Agreeable	Agreeable	Agreeable
3	Turbidity	NTU	1	5	1.1
4	pH at 25 °C	--	6.5-8.5	No relaxation	7.24
5	Electrical Conductivity	µS/cm	-	-	380
6	Total Dissolved Solids	mg/L	500(Max)	2000(Max)	247
7	Total Alkalinity	mg/L	200(Max)	600(Max)	100
8	Total Hardness	mg/L	200(Max)	600(Max)	168
9	Calcium as Ca	mg/L	75(Max)	200(Max)	39
10	Magnesium as Mg	mg/L	30(Max)	100(Max)	17
11	Iron	mg/L	1.0(Max)	No relaxation	0.10
12	Chloride	mg/L	250(Max)	1000(Max)	42
13	Fluoride	mg/L	1.0(Max)	1.5(Max)	0.13
14	Ammonical-Nitrogen	mg/L	0.5(Max)	No relaxation	BDL
15	Nitrate	mg/L	45(Max)	No relaxation	3.8
16	Sulphate	mg/L	200(Max)	400(Max)	51.5
17	Residual Chlorine	mg/L	0.2 (Min.)	1.0(Max)	BDL
18	Coliform Count at 37 ⁰ (MPN)	/100 mL	Absent	No relaxation	0

*BDL=Below Detection Limit


.....End of Report.....

Remarks: RO water sample confirm above specification for the tested parameters and can be considered for the drinking purpose.


 Tested by
 Lab.Tech.


 Verified for Chemical parameters
 Asstt. Chemist


 Verified for MPN
 Asstt. Bact.


 Authorized by
 Chemist


 ACWA(WZD)

Asstt. Chief Water Analyst
 D.J.B. (Govt. of N.C.T. of Delhi)
 Water Works, Wazirabad



MUNICIPAL CORPORATION OF DELHI
(PUBLIC HEALTH DEPARTMENT: CIVIL LINES ZONE)
16 RAJ PUR ROAD, DELHI – 110054



DHO/CLZ/2024/.....1468

Dated: 24/10/24

SCHOOL HEALTH CERTIFICATE

NAME OF THE SCHOOL : M/S Delhi University Social Centre School
at Block-C, Maurice Nagar, Delhi-110007

: No of Student : BOYS- 273, GIRLS-160- TOTAL-433

: No of Staff Members : 20

: Date of Inspection : 23.10.2024

- Rooms are having properly white washed, ventilated and having adequate lighting.
- Drinking water: Delhi Jal Board-Water supply with RO fitted water coolers are installed at each floor for student.
- No of Class Rooms : 10
- No of Toilets : Boys-6, Girls- 4, Staff-2 Total- 12

Sanitation & Hygiene : General sanitation and hygiene are properly maintained in the school and is satisfactory from Health point of view.

In view of the above submissions this health certificate is being issued in favor of the school by undersigned, after being fully satisfied and having **NO OBJECTION FROM HEALTH POINT OF VIEW.**

The above certificate is valid for one year from date of issue.

Dy. Health Officer

Civil Lines Zone

Deputy Health Officer

Civil Lines Zone

Municipal Corporation of Delhi
16, Rajpur Road, Delhi-110054

Vice Principal, HOS

M/S Delhi University Social Centre School
at Block-C, Maurice Nagar, Delhi-110007